

Valparaiso Fire inspection message Inbox x



Tim Stites <TStites@valpo.us>

Mon, Nov 16, 11:02 AM (11 days ago)



to Lvera@meridiantitle.com, jwolf@shive-hattery.com, alyssaschimmel@gmail.com, northwestindianagroup@thrivent.com, manager@m

Dear Valued Customer,

The Valparaiso Fire Department has had to again suspend its inspection program until further notice. We have done this due to the increasing stress the Coronavirus (COVID-19) is causing to local businesses and its owners. We want everyone to stay safe during this time and focus on what is important. Please continue to follow ISDH and CDC guidelines to keep yourself and your families safe. Some of you will be receiving follow up emails from your inspector. They will be attempting to clear violations virtually. Please bear with us. We are here to serve you and the community. If you have any questions for the fire department, please call 219-462-8325.

Respectfully,

Tim Stites
Division Chief/Fire Marshal
Community Risk Reduction Division
Valparaiso Fire Department
Ph:219-548-4849 Cell: 219-252-6469
Fax: 219-531-8812

Reply

Reply all

Forward



Bureau of Fire Prevention

PH: 219-548-4849
FAX: 219-531-8812

2605 Cumberland Dr.
Valparaiso, IN 46383

Occupant Name:	College of Court Reporting	InspectionType:	Reinspection
Address:	455 LINCOLNWAY	Inspection Date:	12/19/2019
Suite:	A		
City:	Valparaiso		
State:	IN		
Zip Code:	46383		

Inspected By: Mike Cervik
mcervik@valpo.us

Insp. Result	Location	Code Set	Code
VIOLATION NOTED - Cleared	Floor 1	Indiana Fire Code 2014 Section 906 Portable Fire Extinguishers	906.2 - Extinguisher annual tag

 **Violation cleared on 12/19/2019**

An inspection of the above property has been conducted. During this inspection, conditions affecting fire & life safety were noted to be in violation of the 2014 Indiana Fire Code, **675 IAC 22-2.5** Thank you for your cooperation in keeping your business and our community safe!

If you have any questions or concerns, please contact us at 219-548-4849.

Company Representative: 
Kathleen Ferlus
12/19/2019
Signature valid only in mobile-eyes documents

Inspector: 
Mike Cervik
12/19/2019
Signature valid only in mobile-eyes documents